Certificate Number 20211109-E341165 Report Reference E341165-20210317 Issue Date 2021-11-09 Issued to: Enphase Energy Inc.

55

1420 N. McDowell Blvd. Petaluma, CA 94954-6515

This is to certify that representative samples of

Grid Support, Utility Interactive Supporting Energy Storage, Multimode, Bi-directional Microinverters

Models IQ8-60, IQ8PLUS-72, IQ8M-72, IQ8A-72, IQ8H-208-72, IQ8H-240-72, may be f/b -2, -5, -E, or -M, may be f/b -ACM, f/b -US, may be f/b -NM, may be f/b - RMA, may be f/b -&, where "&" designates additional characters

Has been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

#### Standard(s) for Safety: Additional Information:

See page 2

See the UL Online Certifications Directory at <u>www.ul.com/database</u> for additional information

This *Certificate of Compliance* is provided as a courtesy to help our customers communicate product compliance information, as documented in our UL Follow-Up Services procedure. This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark shall be considered as being UL Certified and covered under UL's Follow-Up Services. Look for the UL Certification Mark on the product.

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.

a mall

Bruce Mahrenholz, Director North American Certification Program



Certificate Number Report Reference Issue Date 20211109-E341165 E341165-20210317 2021-11-09

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Standards for Safety:

- UL 62109-1, STANDARD FOR SAFETY OF POWER CONVERTERS FOR USE IN PHOTOVOLTAIC POWER SYSTEMS - PART 1: GENERAL REQUIREMENTS, Edition 1, Revision Date 04/30/2019
- IEC 62109-2, SAFETY OF POWER CONVERTERS FOR USE IN PHOTOVOLTAIC POWER SYSTEMS - PART 2: PARTICULAR REQUIREMENTS FOR INVERTERS, Edition 1, Issue Date 06/2011
- UL 1741, Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources, Edition 2, Revision Date 06/10/2021, including the requirements in UL 1741 Supplement SA, sections as noted in the Technical considerations.
- IEEE 1547, IEEE Standard for Interconnecting Distributed Resources with Electric Power Systems.
- IEEE 1547.1, IEEE Standard for Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems.
- CSA C22.2 No. 62109-1, Safety of Power Converters for Use in Photovoltaic Power Systems -Part 1: General Requirements, Edition 1, Issue Date 07/2016
- CSA C22.2 No. 62109-2, Safety of Power Converters for Use in Photovoltaic Power Systems -Part 2: Particular Requirements for Inverters, Edition 1, Issue Date 07/2016

Ba Mell

Bruce Mahrenholz, Director North American Certification Program



Certificate Number Report Reference Issue Date 20211109-E341165 E341165-20210317 2021-11-09

Components covered by this certificate provide functionality in compliance with UL 1741 Supplement A (SA) when used in a UL Listed end product which has been evaluated by UL for it's intended purpose. Compliance testing was conducted on samples of the products according to the test methods in the following sections of UL 1741 with compliant results, and product ratings were reviewed for fulfillment of the requirements in the following SRDs:

Grid Support Function	Source Requirement Document(s)	Test Standard(s) and Section(s)	NRTL Certified Date N/A	
TRANSIENT OVERVOLTAGE (TrOV-2)	HECO APPENDIX 1: Transient Overvoltage Self-Certification Instructions	N/A		
LOW/HIGH VOLTAGE RIDE-THROUGH	SRD 14H V1.1: Part II.C. Table 4	UL 1741 SA 9	2021-03-17	
LOW/HIGH FREQUENCY RIDE- THROUGH	SRD 14H V1.1: Part II.D.1 Table 5	UL 1741 SA 10	2021-03-17	
RAMP RATES	SRD 14H V1.1: Part II.G.1	UL 1741 SA 11.2	2021-03-17	
RECONNECT BY "SOFT START"	SRD 14H V1.1: Part II.G.2	UL 1741 SA 11.4	2021-03-17	
SPECIFIED POWER FACTOR	SRD 14H V1.1: Part II.A.1	UL 1741 SA 12	2021-03-17	
DYNAMIC VOLT/VAR OPERATIONS	SRD 14H V1.1: Part II.A.2 Table 2, Figure 2	UL 1741 SA 13	2021-03-17	
FREQUENCY-WATT	SRD 14H V1.1: Part II.F Table 7	UL 1741 SA 14	2021-03-17	
VOLT-WATT	SRD 14H V1.1: Part II.B Table 3, Figure 3	UL 1741 SA 15	2021-03-17	
DISABLE PERMIT SERVICE		UL 1741 SA 17	2021-03-17	
LIMIT ACTIVE POWER		UL 1741 SA 18	2021-03-17	

An enumeration of functions tested, including complete ratings, and available certified settings for the Grid Support functions, are recorded in the appendix to this document. Test data and detailed results of compliance testing are retained in the complete UL Report for this product.

Barnelly

Bruce Mahrenholz, Director North American Certification Program

Certificate Number Report Reference Issue Date 20211109-E341165 E341165-20210317 2021-11-09

#### Appendix

Detailed Testing Summary	Test Standard(s) and Section(s)	Fixed / Adjustable	Pass / Fail
UNINTENTIONAL ISLANDING WITH GRID SUPPORT FUNCTIONS ENABLED	UL 1741 SA 8	Adjustable	Pass
HIGH VOLTAGE RIDE-THROUGH DURATION	UL 1741 SA 9.1	Adjustable	Pass
HIGH VOLTAGE RIDE-THROUGH / MUST TRIP MAGNITUDES	UL 1741 SA 9.2	Adjustable	Pass
HIGH VOLTAGE MUST TRIP CLEARING TIMES	UL 1741 SA 9.2	Adjustable	Pass
LOW VOLTAGE RIDE-THROUGH DURATION	UL 1741 SA 9.1	Adjustable	Pass
LOW VOLTAGE RIDE-THROUGH / MUST TRIP MAGNITUDES	UL 1741 SA 9.2	Adjustable	Pass
LOW VOLTAGE MUST TRIP CLEARING TIMES	UL 1741 SA 9.2	Adjustable	Pass
HIGH FREQUENCY RIDE-THROUGH DURATION	UL 1741 SA10.1	Adjustable	Pass
HIGH FREQUENCY RIDE-THROUGH / MUST TRIP MAGNITUDES	UL 1741 SA10.2	Adjustable	Pass
HIGH FREQUENCY MUST TRIP CLEARING TIMES	UL 1741 SA10.2	Adjustable	Pass
LOW FREQUENCY RIDE-THROUGH DURATION	UL 1741 SA10.1	Adjustable	Pass
LOW FREQUENCY RIDE-THROUGH / MUST TRIP MAGNITUDES	UL 1741 SA10.2	Adjustable	Pass
LOW FREQUENCY MUST TRIP CLEARING TIMES	UL 1741 SA10.2	Adjustable	Pass
NORMAL RAMP RATE	UL 1741 SA 11.2	Adjustable	Pass
"SOFT START" RAMP RATE	UL 1741 SA 11.4	Adjustable	Pass
SPECIFIED POWER FACTOR	UL 1741 SA 12	Adjustable	Pass
VOLT/VAR MODE (Q(V))	UL 1741 SA 13	Adjustable	Pass
FREQUENCY-WATT (FW)	UL 1741 SA 14	Adjustable	Pass
VOLT-WATT (VW)	UL 1741 SA 15	Adjustable	Pass
DISABLE PERMIT SERVICE	UL 1741 SA17		Pass
LIMIT ACTIVE POWER	UL 1741 SA18	Adjustable	Pass

Bampley

Bruce Mahrenholz, Director North American Certification Program UL LLC



Certificate Number Report Reference Issue Date 20211109-E341165 E341165-20210317 2021-11-09

Inverter Firmware Version:	XXX	$\times$ $\times$ $\times$ $\times$
UL 1998 (grid support)	Date	Version/Revision
YES	2021-02-10	V2.19.01
YES	2021-03-15	V2.22.02
YES	2021-03-24	V2.23.01
YES	2021-06-22	V2.27.02
YES	2021-09-17	V2.38.02
YES	2021-11-03	V2.38.03

Inverter Ratings - Output	240V	208V	Unit
Output phase configuration		L-L	
Nominal (line to line) output voltage V ac	240	208	V
Operating voltage range V ac	211-264	183-229	V
Normal out frequency Hz	60	60	Hz
Rated output current (A ac)	1.6	1.73	Α
Rated output power, (W)	384	360	W

Ratings output per specific model described below:	240 V	208 V
Rated output current (A ac) IQ8H	1.58	1.73
Rated output power (W) IQ8H	380	360
Rated output current (A ac) IQ8A	1.45	
Rated output power (W) IQ8A	349	
Rated output current (A ac) IQ8M	1.35	L / Y
Rated output power (W) IQ8M	325	
Rated output current (A ac) IQ8PLUS	1.21	L. V.H.
Rated output power (W) IQ8PLUS	290	LVL
Rated output current (A ac) IQ8	1.0	$\langle \cdot \rangle$
Rated output power (W) IQ8	240	I. (H.

Bamely

Bruce Mahrenholz, Director North American Certification Program



Certificate Number Report Reference Issue Date 20211109-E341165 E341165-20210317 2021-11-09

Manufacturers stated accuracy of Voltage measurement L-L	MSAvL-L	1.00%	%Vnom	
Manufacturers stated accuracy of Voltage measurement L-N	MSAvL-N	1.00%	%Vnom	
	% based limits			
Manufacturer's stated accuracy of	0.033	Minimum accuracy (sec)		
time response (for Voltage trips) stated in percent, with fixed	5.000	Time setting below which minimum accuracy applies (Sec)		
minimum limits	1.00%	Percent (%) accuracy above minimum time setting.		

Manufacturers stated accuracy of frequency measurement	MSAHz	0.10	Hz
	% based limits		
Manufacturer's stated accuracy of time response (for Frequency trips) stated in percent, with fixed minimum limits	0.033	Minimum accuracy (sec)	
	5.000	Time setting below which minimum accurac applies (Sec)	
	1.00%	Percent (%) accuracy above minimum time setting.	

Other ratings:	
Max. output fault current (A) / duration (ms)	52 A rms for 100 ms
Max. utility backfeed current to PV input (A)	0.018 A
Line Synchronization Characteristics / In-rush current	Method 2 / 0.57 A
Enclosure Ratings	Туре 6
Operating Temperature range	-40°C to 60°C

INTERCONNECTION INTEGRITY TEST CATEGORIES:	
C62.42.2 Ring Wave Surge Category	Category B (6kV)
C62.42.2 Combination Wave Surge Category	Category B (6kV, 3kA)
C37.90.1 RF Immunity - compliance	Yes
C37.90.2 Communication circuit - compliance	N/A

Bamely

Bruce Mahrenholz, Director North American Certification Program



Certificate Number Report Reference

**Issue Date** 

20211109-E341165 E341165-20210317 2021-11-09

<u>Magnitude and time Limits</u> - Utility interconnection voltage magnitude limits, Ride Through time limits and trip times:

Nominal voltage	Single / Split phase					
UL 1741 SA9:	Magnitudes Ride Throug (% of nominal) (Seconds) (-		•	•		
Boundary designation (++)	Min	Max	Min	Max	Min	Max
HV3	106%	122%	0.000	0.000	0.100	0.500
HV2	104%	120%	0.300	19.800	0.160	20.000
HV1	102%	120%	0.800	299.800	1.000	300.000
LV1	70%	98%	0.300	299.800	0.500	300.000
LV2	50%	96%	0.100	149.800	0.200	150.000
LV3	48%	94%	0.600	29.800	0.100	30.000
LV4	0%	0%	0.000	0.000	0.000	0.000

<u>Magnitude and time Limits</u> - Utility interconnection Frequency magnitude limits, Ride Through time limits and trip times:

Nominal Frequency:	60 Hz	<u> </u>	., VU	ЧГУЛ	<b>. 八 ╹ L ノ</b>	ULV.
UL 1741 SA10:	Magnitudes (Frequency)					t Trip onds)
Boundary designation	Min	Max	Min	Max	Min	Max
HF3	0.00	0.00	0.000	0.000	0.000	0.000
HF2	60.10	66.00	0.000	0.000	0.100	1000.0
HF1	60.10	66.00	0.3	999.0	0.5	1000.0
LF1	50.00	59.90	0.3	999.0	0.5	1000.0
LF2	49.90	57.00	0.000	0.000	0.100	1000.0
LF3	0.00	0.00	0.000	0.000	0.000	0.000

SA11 Ramp Rate test ratings (RR/SSRR)

Minimum <b>normal</b> ramp-up rate	1.0 %	%Irated/SEC
Maximum normal ramp-up rate	100 %	%Irated/SEC
Minimum <b>soft start</b> ramp-up rate	0.1 %	%Irated /SEC
Maximum soft start ramp-up rate	100 %	%Irated /SEC

SA12 SPF Specified Power Factor (INV3)	ՍՆՍՆՍՆՍ
Minimum Inductive (Underexcited) Power Factor (<0)	- 0.85
Minimum Capacitive (Overexcited) Power Factor (>0)	+ 0.85

Barnelly

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Certificate Number Report Reference Issue Date 20211109-E341165 E341165-20210317 2021-11-09

Settings		Qmax Values – Minimums	Qmin Values – Maximums	Units
Reactive power production setting	Q1	0.00	0.53	VAR
Reactive power absorption setting at the left edge of the deadband	Q <sub>2</sub>	-0.53	0.53	VAR
Reactive power absorption setting at the right edge of the deadband	Q <sub>3</sub>	-0.53	0.53	VAR
Reactive power absorption setting	Q4	-0.53	0.00	VAR

Settings		Minimum	Maximum	Units	
The voltage at Q1	V <sub>1</sub>	0.80	0.98	%Vnom	
The voltage at Q <sub>2</sub>	V2	0.90	1.00	%Vnom	
The voltage at Q <sub>3</sub>	V <sub>3</sub>	1.00	1.10	%Vnom	
The voltage at Q <sub>4</sub>	V4	1.02	1.19	%Vnom	

SA14 Frequency-Watt (FW) extent of curve range settings					
Settings		Frequency		Power level	
Low end of the adjustment range of the start of the curtailment function	Fstart_min	60.017	58.000	%Watts	
High end of the adjustment range of the start of the curtailment function	F <sub>start_max</sub>	62.000	59.983	%Watts	
Low end of the adjustment range of the endpoint of the curtailment function	F <sub>stop_min</sub>	0.008	0.008	%Watts	
High end of the adjustment range of the endpoint of the curtailment function	F <sub>stop_max</sub>	0.083	0.083	%Watts	

Bampley

Bruce Mahrenholz, Director North American Certification Program

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/



Page 8 of 9

**Certificate Number** 

**Report Reference Issue Date** 

20211109-E341165 E341165-20210317 2021-11-09

Settings		Volts		Power level	
Low end of the adjustment range of the start of the curtailment function	V <sub>start_min</sub>	101%	100%	%Watts	
High end of the adjustment range of the start of the curtailment function	V <sub>start_max</sub>	109.0%	100 %	%Watts	
Low end of the adjustment range of the endpoint of the curtailment function	Vstop_min	102.5%	0 %	%Watts	
High end of the adjustment range of the endpoint of the curtailment function	V <sub>stop_max</sub>	115.0%	0 %	%Watts	

Bamely

Bruce Mahrenholz, Director North American Certification Program UL LLC